

TABLE P2103.6							
WATER-SUPPLY FIXTURE-UNIT VALUES FOR VARIOUS PLUMBING FIXTURES AND FIXTURE GROUPS				Wood Project			
TYPE OF FIXTURES OR GROUP OF FIXTURES	WATER SUPPLY FIXTURE-UNIT VALUE (w.s.f.u.)			Item	Hot	Cold	Combined
	Hot	Cold	Combined				
Bathtub (with/without overhead shower head)	1.0	1.0	1.4				
Clothes washer	1.0	1.0	1.4				
Dishwasher	1.4	---	1.4				
Full-bath group with bathtub (with/without shower head) or shower stall	1.5	2.7	3.6	2	3.0	5.4	7.2
Half-bath group (water closet and lavatory)	0.5	2.5	2.6	1	0.5	2.5	2.6
Hose bibb (sillcock) ^a	---	2.5	2.5	4		10.0	10.0
Kitchen group (dishwasher and sink with/without garbage grinder)	1.9	1.0	2.5	1	1.9	1.0	2.5
Kitchen sink	1.0	1.0	1.4				
Laundry group (clothes washer standpipe and laundry tub)	1.8	1.8	2.5	1	1.8	1.8	2.5
Laundry tub	1.0	1.0	1.4				
Lavatory	0.5	0.5	0.7				
Shower stall	1.0	1.0	1.4				
Water closet (tank type)	---	2.2	2.2				
				Total =	7.2	20.7	24.8
For SI: 1 gallon per minute = 3.785 L/m.							
a. The fixture unit value 2.5 assumes a flow demand of 2.5 gpm, such as for an individual lawn sprinkler device. If a hose bibb/sill cock will be required to furnish a greater flow rate, the equivalent fixture-unit value may be obtained from Table P2903.6 or Table P2903.7.							